



# The Mizoram Gazette

## EXTRA ORDINARY

### Published by Authority

RNI No. 27009/1973

Postal Regn. No. NE-313(MZ) 2006-2008

VOL - XLVIII Aizawl, Monday 22.7.2019 Ashadha 31, S.E. 1941, Issue No. 499

#### NOTIFICATION

**No. H. 11019/3/18-JERC, the 17<sup>th</sup> July, 2019.** In exercise of powers conferred under Section 50 read with Clause (x) of Sub-section (2) of Section 181 of the Electricity Act, 2003 (36 of 2003), and all other powers enabling it in this behalf, the Joint Electricity Regulatory Commission for Manipur & Mizoram hereby makes the following Regulations to amend the Joint Electricity Regulatory Commission for Manipur & Mizoram (Electricity Supply Code) Regulations, 2013 (hereinafter referred to as "the Principal Regulations"), namely;

1. ***Short title and commencement***

- (1) This Regulation may be called the Joint Electricity Regulatory Commission for Manipur & Mizoram (Electricity Supply Code) (Thirteenth Amendment) Regulations, 2019.
- (2) This Regulation shall extend to the whole States of Manipur and Mizoram and shall apply in relation to all matters falling within the jurisdiction of the Commission.
- (3) This Regulations shall come into force from the date of their notifications in the Official Gazette of the concerned States.

2. ***Amendment in Regulation 3 of the Principal Regulations:***

Clause 3.1(2) of the Joint Electricity Regulatory Commission for Manipur and Mizoram (Electricity Supply Code) Regulations, 2013 shall be substituted as below:

3.1(2) At the point of commencement of supply, except with the written consent of the consumer or with the previous sanction of the Commission, a supplier shall not permit the voltage to vary from the declared voltage more than stipulated below or the limit specified by Central Electricity Authority from time to time.

(a) Plus(+)/Minus(-) 6% in respect of Low Tension.

i.e. (1) **Single phase supply**

Minimum: 216V (phase to neutral)

Maximum: 244V (phase to neutral)

(2) **3 phase supply**

Minimum: 376V (phase to phase)

Maximum: 424V (phase to phase)

- (b) Plus(+)/Minus(-) 9% in respect of High Tension.
  - i.e. (1) 11kV system
    - Minimum: 10kV (phase to phase)
    - Maximum: 12kV (phase to phase)
  - (2) 33kV system
    - Minimum: 30kV (phase to phase)
    - Maximum: 36kV (phase to phase)
  
- (c) In respect of Extra High Tension.
  - i.e. (1) 132kV system
    - Minimum: 122kV (phase to phase)
    - Maximum: 145kV (phase to phase)
  - (2) 400kV system
    - Minimum: 380kV (phase to phase)
    - Maximum: 420kV (phase to phase)

Provided that even if the state transmission licensee/utility does not receive regulated voltage from the inter-state transmission licensee/utility, it shall be the duty of the state transmission licensee to deliver regulated voltage to the distribution licensee/utility within the specified limits and it shall be the duty of distribution licensee/utility to deliver regulated voltage to the consumer within the specified limit in the licensed area of operation.

By Order of the Commission

**Richard Zothankima,**  
Assistant Secretary.