



The Mizoram Gazette

EXTRA ORDINARY

Published by Authority

RNI No. 27009/1973 Postal Regn. No. NE-313(MZ) 2006-2008 Re. 1/- per page
VOL - XLIII Aizawl, Thursday 10.7.2014 Asadha 19, S.E. 1936, Issue No. 349

NOTIFICATION

No. H. 11019/14/09-JERC, the 7th July, 2014. In exercise of the powers conferred under Section 181 of the Electricity Act, 2003 and all other powers enabling it in this behalf, the Joint Electricity Regulatory Commission for Manipur and Mizoram makes the following Regulations to amend the Joint Electricity Regulatory Commission for Manipur and Mizoram (Grid Code) Regulations, 2010, hereinafter referred to as "the Principal Regulations" namely:

1. *Short title and commencement*

- (1) This Regulations may be called the Joint Electricity Regulatory Commission for Manipur and Mizoram (Grid Code) (First Amendment) Regulations, 2014.
- (2) This Regulations shall extend to the whole States of Manipur and Mizoram and shall apply in relation to all matters falling within the jurisdiction of the Commission.
- (3) This Regulations shall come into force from the date of their notifications in the Official Gazette of the concerned States.

2. *Amendment in Regulation 2 of the Principal Regulations:*

The sub-regulations (xxxv), (xxxxiii) and (xxxxxvi) of Regulation 2 shall be substituted respectively with the following:

- (xxxv) "**Extra High Voltage (EHV)**" or "**Extra High Tension (EHT)**" means the voltage, which exceeds 33,000 volts under normal conditions subject to the percentage variation allowed by the Central Electricity Regulatory Commission.
- (xxxxiii) "**High Voltage (HV)**" or "**High Tension (HT)**" means the voltage, higher than 440 volts, but which does not exceeds 33,000 volts, under normal conditions subject to the percentage variation allowed by the Central Electricity Regulatory Commission.
- (xxxxxvi) "**Low Voltage (LV)**" or "**Low Tension (LT)**" means the voltage, which does not exceeds 230 volts at single phase and 440 volts at three phase under normal conditions subjects, however, to the percentage variation allowed by the Central Electricity Regulatory Commission.

3. *Amendment in Regulation 5 of Principal Regulations:*

The sub-regulation (3) of Regulation 5: Grid Code Regulations is applicable for system dealing with voltage of 33 kV and above shall be substituted with the following:

(3) Grid Code Regulations is applicable for system dealing with voltage above 33 kV.

By Order of the Commission

Richard Zothankima,
Assistant Secretary.